

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing
A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

TEST REPORT

Client : Eco Flooring Systems Pty Ltd
1/180 Toongabbie Road
Girraween NSW 2145

Test Number : 20-004764
Issue Date : 7/10/2020
Print Date : 9/10/2020

Sample Description Clients Ref : "Ornato Hybrid Flooring"
Hybrid flooring planks
Colour : Various
End Use : Residential & Commerical Flooring
Nominal Composition : Limestone, Plastic
Nominal Mass per Unit Area/Density : 1000g/m2
Nominal Thickness : Approx 7mm

AS 4586-2013 Appendix A

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing	07/10/2020					
Test Temperature (20±5degC)	20 °C					
Sample Preparation	Samples washed with pH neutral detergent and dried					
Test Direction	Length					
Fixed/Unfixed	Unfixed					
Slider No 96 Batch No	95					
Length	1	2	3	4	5	SRV
British Pendulum Number	30	31	30	30	30	30
Classification	P2					

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.

217082

46694

Page 1 of 1

© Australian Wool Testing Authority Ltd
Copyright - All Rights Reserved



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.

APPROVED SIGNATORY



MICHAEL A. JACKSON B.Sc. (Hons)
MANAGING DIRECTOR