

AWTA PRODUCT TESTING

Australian Wool Testing Authority Ltd - trading as AWTA Product Testing

A.B.N 43 006 014 106

1st Floor, 191 Racecourse Road, Flemington, Victoria 3031

P.O Box 240, North Melbourne, Victoria 3051

Phone (03) 9371 2400

TEST REPORT

Client : Eco Flooring Systems Pty Ltd
1/180 Toongabbie Road
Girraween NSW 2145

Test Number :

Issue Date : 20-004764

Print Date : 7/10/2020

Date : 9/10/2020

Sample Description Clients Ref : "Ornato Hybrid Flooring"
Hybrid flooring planks
Colour : Various
End Use : Residential & Commercial Flooring
Nominal Composition : Limestone, Plastic
Nominal Mass per Unit Area/Density : 2000g/m²
Nominal Thickness : Approx 7mm

**AS 4586-2013
Appendix A**

Slip Resistance Classification of new Pedestrian Surface Materials Wet Pendulum Test Method

Date of Testing						07/10/2020
Test Temperature (20±5degC)						23 °C
Sample Preparation	Samples washed with pH neutral detergent and dried					
Test Direction	Length					
Fixed/Unfixed						Unfixed
Slider No 96 Batch No						95
Length	1	2	3	4	5	SRV
British Pendulum Number	39	40	39	38	37	38
Classification						P3

Equipment: Cooper Pendulum Skid Tester Serial No: 1433-01 Calibrated 08/11/2019
Slider prepared using P400 and 3µm lapping film.

These results apply only to the specimens tested and it is recommended that before selection of flooring or paving materials the effect of service conditions, including maintenance and wear on their slip resistance be checked.



Accredited for compliance with ISO/IEC 17025 - Testing

Samples and their identifying descriptions have been provided by the client unless otherwise stated. AWTA Ltd makes no warranty, implied or otherwise, as to the source of the tested samples. The above test results relate only to the sample or samples tested. This document shall not be reproduced except in full and shall be rendered void if amended or altered. This document, the names AWTA Product Testing and AWTA Ltd may be used in advertising providing the content and format of the advertisement have been approved by the Managing Director of AWTA Ltd.



0204/11/06

A blue ink signature, appearing to be "A. D. D.", written in a cursive style.

APPROVED SIGNATORY

A blue ink signature, appearing to be "Michael A. Jackson", written in a cursive style.

MICHAEL A. JACKSON B.Sc.(Hons)
MANAGING DIRECTOR